



FACILITY ID NUMBER 2811

DEPARTMENT OF PUBLIC WORKS - WATER SERVICES DIVISION
Big Creek WRP 1030 Marietta Highway Roswell, GA 30075

TELEPHONE: 4-612-9440 FAX: 4-224-5315

FULTON COUNTY PERMIT INSPECTION REPORT

Fulton County Sewer Use Ordinance, Section 82-251
Commercial Wastewater Pretreatment

NAME OF FACILITY: INC Street Food DATE: 10-20-09 TIME: 11:00

ADDRESS: 918 CANTON ST Roswell GA
Street/Number City State Zip Code

CONTACT NAME: LAWIS HREN TELEPHONE NO: 404-610-2024

TYPE OF FACILITY: RESTAURANT
(food service)

TYPE OF PRETREATMENT SYSTEM: exterior interior grease trap oil separator manual
 AGRU GPM

PRETREATMENT SIZE/NUMBER: 1 1000 1500 3000 40# 70# other

Inspection Type: Preliminary Re-inspection Date / / Inspection No.

Photo Survey Final
After a preliminary inspection has been conducted, the contractor has (7) seven days to complete the corrective action. If the site cannot be approved upon re-inspection, any subsequent inspections will be \$50.00 each until the site is approved. The total inspection cost will include this additional charge. APPROVED NOT APPROVED

Re-inspection Cost: \$50.00 x = \$

Corrective Action:

- Install pre-treatment system according to Fulton County engineering standards; stamped and signed by Commercial PT
- Bring manholes & cleanouts up to grade
- Install test manhole max. (6) feet from last tank(s)
- Install correct tank number and/or size
- Install 2"-4" crusher run
- Construct invert in test manhole
- Install baffle in tank w/elbow PVC pipe
- Install 6" outlet tee
- Post signs as required for car wash
- Install flow control valve; and/or vent line
- Install 6" inlet tee
- Install test MH w/1 foot drop
- Remove additional discharge lines from pre-treatment system and/or test manhole
- Provide accessibility for inspection
- Provide maintenance letter and/or tank invoice
- Grout around all piping as required
- Install pre-treatment system w/ PDI certification
- Remove or repair tank; tank cracked or damaged
- WARNING NOTICE: (exterior tanks only)**
Dig up site; unable to conduct preliminary inspection, tanks covered up. Cannot verify system is installed as required. Contractor must comply with construction checklist.

Final Inspection (\$100.00)
(Check or money order payable to Fulton County Public Works)

Site Permit Number:

Approved:
Pretreatment system installed per Fulton County engineering standards and is approved to discharge to sanitary sewer.
(includes any re-inspection fees) \$ 100.00

Notice Issued to: LAWIS HREN
PRINT NAME / POSITION

Inspector Name: TERRY HEARD Ext.
PRINT NAME

INSPECTOR (WHITE)

CONSTRUCTION SITE